

CERTIFICATE OF CONFORMITY

Product :

Electric cables for photovoltaic systems with a voltage rating of 1,5 kV DC

Tested by request of:

Yusuf Kabukçu Nak Kablo Elektrik Malz. İnşaat
İnşaat İthalat İhracat San. Tic. LTD. ŞTİ.
Bozburun Mah. 7045 Sok. No:9 Merkezefendi
Denizli Türkiye

Rating and principal characteristics:

1,0/1,0 kV ,
Rated Temperature -40°C to +90°C
Maximum conductor temperature 120°C

Trade mark (if any)

NAK SOLAR CABLE

Model/Type ref:

1x1,5 mm²- 1x240 mm²


Additional information (if any)

A sample of the product has been tested and found to be in conformity with the current
IEC 62930:2017 & EN 50618 :2014

This statement is the result of testing a sample of the product submitted, in accordance with the
the relevant specific standard



06.08.2021


S. Müge Okumuş
E&E Division Manager

